



NOTE: KEYED NOTES ARE LISTED FOR A5.01 - A5.04 BUILDING SECTIONS. SOME NOTES LISTED BELOW MAY NOT APPLY TO THIS SHEET.

01 SECTION
SCALE: 3/8"=1'-0"

- SECTION KEY NOTES**
- NOTE: KEYED NOTES ARE LISTED FOR A5.01 - A5.06 BUILDING SECTIONS. SOME NOTES LISTED BELOW MAY NOT APPLY TO THIS SHEET.
- COMPOSITION SHINGLES OVER 15 POUND ROOFING FELT.
 - PLYWOOD ROOF DECKING W/ PLY-CLIPS, 5/8 INCH THICK.
 - ROOF TRUSSES, RE: STRUCTURAL.
 - INSULATION R-30, (BATT).
 - WEEP HOLES @ 3'-0" O.C. MAX. (TYP. ALL EXTERIOR BLOCK VENEER WALLS).
 - GYPSUM WALLBOARD, 5/8 INCH THICK, PAINTED.
 - WOOD STUDS, 2 INCHES X 4 INCHES, RE: STRUCTURAL.
 - WINDOW, RE: SCHEDULE.
 - CERAMIC TILE OVER THIN SET.
 - 3/4" GYP. CONCRETE ON 3/4" T&G PLYWD. DECKING
 - INSULATION R-15 WITH VAPOR BARRIER.
 - CONTINUOUS 2 INCH X 4 INCH WOOD PLATES.
 - FIRESTOP.
 - CONTINUOUS 2 INCH X 6 INCH WOOD PLATES.
 - WOOD FLOOR TRUSS, RE: STRUCTURAL.

- SECTION KEY NOTES (CONT.)**
- WOOD STUDS, 2 INCHES X 6 INCHES AT 16 INCH CENTERS.
 - CYPRESS BOARD SIDING
 - TYVEK HOUSE WRAP.
 - 5/8" GYP. LAP SHEATHING, (FIRE-RATED).
 - FINISH FLOOR, RE: SCHEDULE.
 - CONTINUOUS 2 INCH X 6 INCH DOUBLE WOOD PLATES, TREATED.
 - SCHEDULED WOOD BASE.
 - 20 MIL FLEXIBLE FLASHING AT BASE OF VENEER WALL TO EXTEND UP 8" BEHIND SHEATHING BOARD AND OVERLAP CONC. SILL.
 - GALVANIZED 26 GAUGE METAL DRIP EDGE WITH HEIMED EDGES, PAINTED.
 - METAL GALV. WALL TIES, AS REQUIRED.
 - WOOD TRIM, 1 INCH X 6 INCH, PAINTED.
 - WOOD TRIM, 2 INCH X 4 INCH (KDAT), PAINTED.
 - PRE-CASTE CONCRETE TRIM.
 - TIMBER BEAM, RE: STRUCTURAL.
 - WOOD BLOCKING, 2 INCH X 6 INCH, PAINTED.

- SECTION KEY NOTES (CONT.)**
- NON-VENTED SOFFIT BOARD, -CYPRESS.
 - WOOD STUDS 2"x6"
 - WOOD FASCIA, 2 INCH THK., VERIFY SIZE W/ DETAIL, PAINTED.
 - INSULATION R-19, (BATT).
 - STEEL GALV. METAL ANGLE, RE: STRUCTURAL
 - TRIM, 1 INCH X 6 INCH, PAINTED.
 - FLEXIBLE FLASHING.
 - VENTED SOFFIT BOARD, 1/4 INCH THICK, SMOOTH BY HARDIE.
 - WOOD TRIM, 1 INCH X 4 INCH, PAINTED.
 - CONCRETE SLAB, RE: STRUCTURAL.
 - SMOOTH FACE CONC. COURSE, MATCH SPLIT-FACE C.M.U. COLOR.
 - CONCRETE CAP COURSE, MATCH SPLIT-FACE COLOR.
 - METAL FLASHING, EXTEND UP WALL 8 INCHES.
 - WOOD TRIM, 1 INCH X 2 INCH, PAINTED.
 - WOOD FRAMING, 2X AT 24" O.C.
 - WOOD JOIST, 2 INCH X 6 INCH.
 - U.L. 1-HOUR RATED ASSEMBLY DESIGN L-528 SYSTEM NO.4.
 - 12" THK. C.M.U. WALL.

- SECTION KEY NOTES (CONT.)**
- WOOD LEDGER, 2 INCH X 6 INCH.
 - SCHEDULED WOOD DOOR.
 - 2 LAYERS 5/8" TYPE "C" GYP. BD., 4" OUT FROM THE RATED WALL, BOTH SIDES.
 - ALUMINUM THRESHOLD UNIT, SET IN MASTIC.
 - WOOD TRIM, 2 INCH X 6 INCH, PAINTED.
 - VAPOR BARRIER, 6 MIL. POLYETHYLENE.
 - CONCRETE GRADE BEAM, RE: STRUCTURAL.
 - CONTINUOUS 2 INCH X 6 INCH WOOD PLATES.
 - WOOD TRIM, 2 INCH X 4 INCH, PAINTED.
 - 5/8" TYPE "C" GYP. BD. SCREWED TO METAL RC-1 CHANNELS AT 16" O.C., U.L. L-528 ASSEMBLY.
 - ANCHOR BOLTS, RE: STRUCTURAL. SEAL PLATE WITH FOAM SEALANT.
 - WOOD FASCIA, 2 INCH X 10", RE STRUCTURAL.
 - 2 LAYERS 1" GYP. SHEATHING TYPE "X" (2-HR RATING).
 - WD. STOOL.
 - CONCRETE CURB.
 - SLOPE CONCRETE SLAB FLOOR, (PATIO, HALLWAY).

- SECTION KEY NOTES (CONT.)**
- ROD AND SHELF, RE: SPECS.
 - 5/8" GYP. SOFFIT BD. SCREWED TO METAL CHANNELS OR 5/8" TYPE "G" GOLD BOND GYP. BD. SCREWED DIRECTLY TO TRUSS.
 - STEPS BEYOND, SHOWN DOTTED.
 - 2X6 WD. OUTLOOKER AT 16" O.C.
 - WD. TRUSS W/ CEILING BREAK, RE: STRUCTURAL.
 - CAULK.
 - PRESSURE TREATED WOOD PLATE, 2 INCH X 4 INCH.
 - 1" MIN. GAP BETWEEN SIDING AND ROOFING.
 - PLACE SHINGLES SET IN ROOF MASTIC OVER METAL FLASHING.
 - METAL FLASHING.
 - METAL CORNER BEAD.
 - WOOD HEADER, 2 INCH X, RE: STRUCTURAL.
 - LINE OF SLOPED CEILING.
 - WOOD BLOCKING, 1 INCH X 8 INCH, PAINTED.
 - SLOPED CEILING.
 - "S" TYPE METAL FLUE.

- SECTION KEY NOTES (CONT.)**
- STONE HEARTH
 - PRE-FABRICATED FIREPLACE.
 - 5/8" GYP. BD.
 - STONE VENEER ON WALL
 - FIXED WITH MORTAR
 - 4"x4" BULL-RAIL RAILING, 2X6 HANDRAIL AT TOP
 - SLOPE TO DRAIN.
 - 3/4" WD. CAP.
 - CASEWORK, RE: SPECS.
 - BOTTOM RAIL, METAL, 3/4 INCH X 3/4 INCH.
 - G.I. STEP FLASHING.
 - 2X CORNER TRIM.
 - SC ROUND CHIMNEY CAP.
 - 1-1/2" LIT. WT. CONC. ON 3/4" T&G PLYWD. DECKING OVER 2 PLY HOT MOP WATERPROOFING.
 - CASING, RE: SPECS.
 - ROD AND SHELF, RE: SPECS.
 - AIRSPACE.
 - INSULATION Baffle.

- SECTION KEY NOTES (CONT.)**
- 5/8" FIRE CODE GYP. BD. SCREWED TO METAL RC-1 CHANNELS AT 12" O.C. U.L. DESIGN NO. P-522 (LOOSE INSUL.) OR U.L. DESIGN P-538 (16" O.C. W/ 20 GA. CHANNELS AND JAMES HARDY-TYPE "C" GYP. BD.)
 - MINI EQUALLY SPACED. ANCHOR ALL STRONG BACKS AT BOTTOM CHORD OF ROOF TRUSS WITH BLOCKING AS NECESSARY.
 - HIGH POINT, SHIM, POUR STOP 1/2".
 - FIRE-SAFING.
 - TWO (2) LAYERS 1" TYPE "X" GYP. BD., SET IN C-RUNNERS, SEAL TO DECK AND SLAB BELOW.
 100. GRADE
 101. HIGH POINT, SHIM, POUR STOP 1/2".
 102. FIRE-SAFING.
 103. TWO (2) LAYERS 1" TYPE "X" GYP. BD., SET IN C-RUNNERS, SEAL TO DECK AND SLAB BELOW.
 104. HORIZ. C-RUNNER, RE: A-514 FOR DETAIL.
 105. ANGLE CLIP, RE: A-514 FOR DETAIL.
 106. C-RUNNER, SET IN SEALANT.
 107. NJ-1 METAL CHIMNEY SHROUD.
 108. 26 GA. GALV. METAL CHASE CAP.
 109. 15 # FELT OVER 1/2" CDX PLYWD. SHEATHING.

- SECTION KEY NOTES (CONT.)**
- AT EACH INSIDE CORNER OF THE CHIMNEY CHASE PROVIDE THE FOLLOWING: 2X4X9" STUD STRONG-BACK BRACING TO BOTTOM OF ROOF TRUSS. NAIL STRONG BACK TOGETHER AT 6" O.C. ATTACH STRONG BACK TO INSIDE CORNER OF CHIMNEY CHASE WITH 8 NAILS.
 - MINI EQUALLY SPACED. ANCHOR ALL STRONG BACKS AT BOTTOM CHORD OF ROOF TRUSS WITH BLOCKING AS NECESSARY.
 - REFER TO FIREPLACE MANUFACTURER'S INSTALLATION INSTRUCTIONS TO COMPLY WITH ALL CLEARANCE AND INSTALLATION REQUIREMENTS.
 - SPRING HINGE SIDE.
 - SPRING HINGED 1/2" ACCESS DOOR AP-2 SEE ROOF PLANS FOR LOCATION.
 - 1-1/8" PLYWD. PLATFORM.
 - 2X6 DOOR OPENING FRAME.
 - SF FIRESTOP SPACER AT CEILING LINE ABOVE FIREPLACE BOX.
 - KAPP 22"X30" KRP-350 FR. FIRE RATED ACCESS DOOR W/ FLUSH KEY LOCK.
 - PORTABLE 10' EXTENSION LADDER, SHOWN HIDDEN FOR CLARIFICATION

- SECTION KEY NOTES (CONT.)**
- DEMISING WALL, SHOWN HIDDEN FOR CLARIFICATION.
 - CONTINUOUS 1/2" DRAFTSTOP.
 - 2X6 FRAMING BETWEEN TRUSSES.
 - ACCESS DOOR -AP2, IN CENTER DEMISING WALL.
 - CONTINUOUS DRAFTSTOP ACROSS THIS AREA.
 - METAL CAN DETECTION RAIL.
 - 1-1/2" DIA. METAL HANDRAIL.
 - CLOSED RISER, 14 GA. BENT METAL.
 - 1/2" METAL BALLUSTERS @ 4" O.C.
 - 1-1/2"x1-1/2" STEEL TUBE.
 - MC 10X8.4 CHANNEL STRINGER.
 - 2" PRECASTE CONC. TREADS.
 - STEEL ANGLE SHELF.
 - METAL HANDRAIL WALL BRACKET.
 - METAL SHEATING OVER 3/4" THK. PLYWOOD/WOODEN DECKING
 - 4"x14" TIMBER RAFTERS, TREATED AND PAINTED BELOW ROOF SHEATHING

- SECTION KEY NOTES (CONT.)**
- 1 1/8" THK. T & G WOOD FLOORING
 119. DEMISING WALL, SHOWN HIDDEN FOR CLARIFICATION.
 120. CONTINUOUS 1/2" DRAFTSTOP.
 121. 2X6 FRAMING BETWEEN TRUSSES.
 122. ACCESS DOOR -AP2, IN CENTER DEMISING WALL.
 123. CONTINUOUS DRAFTSTOP ACROSS THIS AREA.
 124. METAL CAN DETECTION RAIL.
 125. 1-1/2" DIA. METAL HANDRAIL.
 126. CLOSED RISER, 14 GA. BENT METAL.
 127. 1/2" METAL BALLUSTERS @ 4" O.C.
 128. 1-1/2"x1-1/2" STEEL TUBE.
 129. MC 10X8.4 CHANNEL STRINGER.
 130. 2" PRECASTE CONC. TREADS.
 131. STEEL ANGLE SHELF.
 132. METAL HANDRAIL WALL BRACKET.
 133. METAL SHEATING OVER 3/4" THK. PLYWOOD/WOODEN DECKING
 134. 4"x14" TIMBER RAFTERS, TREATED AND PAINTED BELOW ROOF SHEATHING

- SECTION KEY NOTES (CONT.)**
- DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).

- SECTION KEY NOTES (CONT.)**
135. 1"6" TIMBER POSTS.
 136. METAL SHEAT FLASHING OVER ROOF JOINTS
 137. DESIGNED WOOD BRACKETS FOR ADDL. STRENGTH (SEE DETAILS)
 138. WOOD WALE/AS NEEDED
 139. 4"x8" FRAMING AT SLOPE END
 140. RIGID INSULATION WITH VAPOR BARRIER AIR GAP(MIN 2")AT TOP (R-30 BATT)
 141. DESIGNED WOOD TRIM (SEE DETAILS)

- SECTION KEY NOTES (CONT.)**
142. DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).

- SECTION KEY NOTES (CONT.)**
143. DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).

- SECTION KEY NOTES (CONT.)**
144. DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).

- SECTION KEY NOTES (CONT.)**
145. DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).

- SECTION KEY NOTES (CONT.)**
146. DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).

- SECTION KEY NOTES (CONT.)**
147. DIAGONAL BRACES TO STRENGTHEN TRUSS
 - METAL PLATE WITH SEAM BOLT AND SCREWED TO WOOD MEMBERS
 - DOUBLE WOOD STUDS, 2 INCHES X 6 INCHES AT -- C/C (RE: STRUCTURAL).